



(70 CFM)

[®]2100 **HVI** Certified **3″ Duct (Standard):** 70 CFM/2.0 Sones @ 0.1 SP, 13.2 Watts 54 CFM/1.5 Sones @ 0.25 SP, 11.6 Watts





Description

Low noise ceiling/wall mount ventilating fan with super low profile, rated for continuous running. ENERGY STAR® qualified. It is HVI, UL, and cUL certified, and can be used to comply with ASHRAE 62.2 (local and whole building intermittent operation).

DC Motor/Blower

- Power rating of 120 volts/60Hz
- DC brushless motor engineered to run continuously
- Motor equipped with thermal cutoff fuse
- Removable with permanently lubricated plug-in motor
- Built-in soft start function to increase bearings' life
- Automatically powers OFF when impeller is locked abnormally

Housing

- Galvanized steel body
- Detachable 3" diameter duct adapter
- Built-in backdraft damper
- Easy installation

Grille

- Attractive design using ABS material
- Attaches directly to housing with torsion springs

LED Indicator

• Turn the power switch on/off to operate on/off. LED indicator will be green when power is on


Warranty


• 3-Year limited warranty

BreezSlim SLM70	3" Duct (Standard)	
Static Pressure (inches w.g.)	0.1	0.25
Air Flow (CFM)	70	54
Sones	2.0	1.5
Power Consumption (Watts)	13.2	11.6
Energy Efficiency (CFM/Watt)	5.8	5.0
Current (Amps)	0.29 Max	
Power Rating (V/Hz)	120 / 60	

TYPICAL SPECIFICATION

Ventilation fan shall be Delta Breez model SLM70; ENERGY STAR qualified with Brushless DC Motor engineered to run continuously for a minimum 70,000 hours; airflow rating of 70 CFM and loudness rating of 2.0 Sones at 0.1 static pressure as certified by the Home Ventilating Institute (HVI); power consumption of not more than 13.2 Watts with efficiency rating of 5.8 CFM/Watt; fan will feature LED indicator running light and motor lock protection. UL and cUL listed for tub/shower enclosure when used with GFCI-protected branch circuit wiring





Tag	Quantity	Comments	Project:
			Location:
			Architect:
			Engineer:
			Contractor:
			Submitted by:
			Date: